According to Annex III of the Regulation (EU) Nr.305/2011 (Construction Products Regulation)

# ASTRO X SERIES® CE PIPE COLLAR

CASTROFLAME MANUFACTURERS OF PASSIVE FIRE STOP PRODUCTS

# 1121-CPR-JA5084

**1. Unique identification code of product-type:** XSPC

# 2.Type, Batch or serial number as required pursuant to Article 11(4):

See ETA 15/0617 : See batch number displayed in product

#### 3. Intended use or uses of construction product, in accordance with the applicable harmonized technical specification:

Fire Stopping and Sealing Products for Penetration Seal, See ETA 15/0617

| Pipe Penetrations Non insulated plastic pipes | The field of application has to comply with the content of ETA 15/0617 |
|---|--|
|---|--|

4. Name, registered trade name or registered trade mark and contact address as required pursuant to article 11(5):

Astroflame Fireseals Ltd, Unit 8, The I O Centre, Stephenson Road, Segensworth, Fareham Hampshire, PO15 5RU

# 5. Authorized representative: N/A

## 6. System or systems of assessment and verification of performance of the construction product as set out in Annex V: AVCP - System 1

## 7. Harmonized standard: N/A

**8.** In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued: Warrington Certification Limited issued European technical approval - ETA 15/0617 on the basis of ETAG 026 part 1 General fire protection products & ETAG 026 part 2 fire stopping and fire sealing products & issued certificate of conformity 1121-CPR-JA5084

## 9. Declared performance:

| Essential Characteristics | Performance/Harmonised technical specification   |
|---------------------------|--|
| Reaction to Fire          | Class E according to EN13051-1   |
| Resistance to Fire        | Resistance to fire performance & field of application in accordance with EN13501-2 See ETA 15/0617 - Annex A   |
| Dangerous Substances      | See ETA 15/0617 Clause 1.5   |
| Service & Durability      | Type: X Intended for use in conditions exposed to weathering in accordance with EOTA technical documents TR024 |
| Other                     | Not applicable/No performance determined   |

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

13/10/2015

Signed for and on behalf of the manufacturer by:

P. Ki<u>es</u>er

**P.Kieser - Managing Director** 

Astroflame Ltd Unit 8, The I O Centre Stephenson Road Segensworth, Fareham Hampshire, PO15 SRU Tel: +44 (0) 1329 844500 Fax: +44 (0) 1329 844600 Email: sales@astroflame.com Website: www.astroflame.com



9. Dicken 13/10/2015

**C.Dickens - Technical Manager**